

Original

# Annexure C

Appendix-XIII

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CMO/3960

Dated: 17/07/23

It is certified that an inspection team headed by Dr. Rohit Gopal Dip.CMO/Pub. Health  
 (Name of Officers with designation) from expert team CMO office Aligarh  
 (Name of Department/ Office) inspected the St. Fidelis School, Kheda Khush Khabas  
 (Name & Address of the school) on 17/07/23 (date of inspection), checked the water test report  
 submitted by the school and found that the school has potable drinking water for students and staff of the  
 institution and is having provision for running water in the toilets and maintaining hygienic sanitation  
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 31/03/24

Signature with Seal: [Signature]

Name: Dr. Rohit Gopal

Designation: Pub. Health exp. / Dip.CMO

Assistant Engineer of  
the Govt. Public Health Department (PHED)/  
Authorised officer of the Local Body

Name & Address of the Office / Department: CMO  
Aligarh

To

St. Fidelis School

Kheda Khush Khabas  
Aligarh

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

58 | Page

[Signature]  
 PRINCIPAL  
 ST. FIDELIS SCHOOL  
 KHEDA KHUSH KHAS  
 ALIGARH

[Signature]  
 MANAGER  
 ST. FIDELIS SCHOOL  
 KHEDA KHUSH KHAS  
 ALIGARH

District Level Water Analysis Laboratory Aligarh  
 Address: First Floor, Office of Superintending Engineer U.P. Jal Nigam (Urban)  
 Aligarh 202001

**Water Test Report**

Report No. AL/DL/CPA/024 Issue Date: 27/06/2023  
 UTR No. TC989123000000024A Page No. 01

Customer Details  
 Office Name and Address: M/s ST FIDELIS SCHOOL  
 Ref Letter No & Date: SFS/APP24-06-2023

Basic details of sample  
 District: Aligarh Block: -  
 Gram Panchayat: - Village / NPP: -  
 Habitation: - Location: M/s ST FIDELIS School Kheda Khush Khabas, Janki Dora Post, Aligarh (U.P.) 202140  
 Water Source: R O Water Sample No: 01  
 Quantity of Sample: 1000 ml Date of Collection: 26/06/2023  
 Receiving Date: 26/06/2023 Sample Collector: Mr. Jojo George  
 Sample Depositor: Mr. Jojo George Sampling Method: As per IS 3025: Part 1:1986  
 Analysis Start Date: 26/06/2023 Analysis Completion Date: 27/06/2023

S No	Analyzed parameters	Unit of Measurement	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH	-	7.41	6.5-8.5	6.5-8.5	IS 3025 (Part 1):2022 (Electrometric method)
2	Turbidity	NTU	0.73	1	5	IS 3025 (Part 10):2017
3	TDS	mg/L	122	500	2000	IS 3025 (Part 16):2017
4	Fluoride	mg/L	0.09	1	1.5	APHA 23 <sup>rd</sup> Edition 4500-F Method C (Electrode method) 7017
5	Total Hardness	mg/L	76	200	600	IS 3025 (Part 21):2019
6	Total Alkalinity	mg/L	92	200	600	IS 3025 (Part 23):2019
7	Chloride	mg/L	16	250	1000	IS 3025 (Part 32):2019
8	Iron	mg/L	0.02	1	1	APHA 23 <sup>rd</sup> Edition 3500-Fe Method B (Phenanthroline Method) 2017
9	Sulphate	mg/L	3.9	200	400	APHA 23 <sup>rd</sup> Edition 4500-SO4 Method E (Turbidity Method) 2017
10	Calcium	mg/L	12.8	75	200	IS 3025 (Part 40):2019
11	Magnesium	mg/L	10.7	30	100	IS 3025 (Part 46):2019
12	Color (Hazen)	-	1	5	15	APHA 23 <sup>rd</sup> Edition Color 2120 B (Visual Comparison Method)
13	Odour	-	Agreeable	-	-	IS 3025 (Part 05):2018
14	E-Coli	CFU	0	-	-	APHA 23 <sup>rd</sup> Edition: 2017
15	Total Coliform	CFU	0	-	-	APHA 23 <sup>rd</sup> Edition: 2017
16	Free Residual Chlorine	mg/L	0	0.5	0.5	IS 3025 (Part 26):2021

Note:  
 1. This Certificate refers only to the sample(s) submitted for testing.  
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.  
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.  
 4. Sample will be stored up to 10 days (in case of non-perishable items only) from the date of issue of tests reports.  
 5. Remark- Parameters above permissible limits are written in bold.

Tested By: [Signature]  
 Yashwant Singh  
 (Deputy Technical Manager)

[Signature]  
 PRINCIPAL  
 ST. FIDELIS SCHOOL  
 KHEDA KHUSH KHAS  
 ALIGARH

[Signature]  
 MANAGER  
 ST. FIDELIS SCHOOL  
 KHEDA KHUSH KHAS  
 ALIGARH

Head of Laboratory  
 District Level Water Analysis Laboratory  
 Aligarh

Laboratory Contact details  
 Email- waterlab.alg@gmail.com Mob- 6350499124